













SYMBOL	DESCRIPTION: (THESE NOTES SPECIFIC TO THIS DRAWING)
--------	---

	FIRE EXTINGUISHER w/ CABINET
	PRIMARY EGRESS
	SECONDARY EGRESS
	AUDIO-VISUAL FIRE ALARM DEVICE, MOUNT 80" A.F.F.
	STROBE FLASHING VISUAL LIGHT, WALL MOUNT 80" A.F.F.
	FIRE ALARM PULL STATION, MOUNT 48" A.F.F.
	SMOKE DETECTOR, SURFACE MOUNTED BELOW CEILING.
WP 	AUDIO FIRE ALARM DEVICE. (WEATHERPROOF)
	EXIT LIGHT
	HEAT DETECTOR

1. FIRE EXTINGUISHERS OF APPROPRIATE TYPE AND SIZE ARE TO BE INSTALLED AND TAGGED BY A LICENSED DEALER AT THE TIME OF SUBSTANTIAL COMPLETION.

WALL TYPE	
1	<p><b>INTERIOR CAVITY WALL WITH BRICK VENEER: (BEARING)</b>              8" CMU LOAD BEARING WALL IN RUNNING BOND PATTERN UP TO JOIST BEARING w/ BOND BEAM @ TOP OF WALL. SEE SECTIONS AND STRUCTURAL FOR ADDITIONAL REQUIREMENTS. PROVIDE CONTINUOUS EYE &amp; PINTEL TRUSS TYPE REINFORCEMENT @ 16" O.C. ADD CORRIGATED TIES AT 16"o.c. BELOW TOP BRICK. APPLY DAMPPROOFING AND INSULATION. FILL ALL VOIDS BETWEEN TOP OF BLOCK AND ROOF DECK WITH SPRAY FOAM INSULATION.</p>
2	<p><b>INTERIOR WALL: (BEARING)</b>              8" INTERIOR C.M.U. LOAD BEARING WALL IN RUNNING BOND PATTERN UP TO JOIST BEARING w/ BOND BEAM @ TOP OF WALL. PROVIDE CONTINUOUS WIRE LADDER OR TRUSS TYPE REINFORCEMENT @ 16" O.C. SEE SECTIONS FOR ADDITIONAL REQUIREMENTS. PROVIDE SMOKE PARTITION SYSTEM AT CORRIDOR WALLS.</p>
3	<p><b>INTERIOR WALL: (NON-BEARING)</b>              8" INTERIOR C.M.U. WALL IN RUNNING BOND PATTERN UP TO A MINIMUM OF 4" ABOVE THE FINISH CEILING w/ BOND BEAM @ TOP OF WALL.. PROVIDE CONTINUOUS WIRE LADDER OR TRUSS TYPE REINFORCEMENT @ 16"O.C. SEE SECTIONS FOR ADDITIONAL REQUIREMENTS. PROVIDE 3 5/8" MTL. STUDS @ 16" O.C. FROM TOP OF CMU UP TO ROOF DECK. PROVIDE TYPE 'X' 5/8" GYP. BOARD ON BOTH SIDE OF STUDS. INSTALL 3/2" BATT INSULATION IN BETWEEN STUDS. FILL ALL VOIDS BETWEEN TOP OF WALL AND ROOF DECK WITH SPRAY FOAM INSULATION.              OMIT SPRAY FOAM AND SUBSTITUTE SMOKE PARTITION SYSTEM AT CORRIDOR WALLS.</p>
4	<p><b>INTERIOR WALL: (NON-BEARING)</b>              8" INTERIOR C.M.U. WALL IN RUNNING BOND PATTERN UP TO A MINIMUM OF 4" ABOVE THE FINISH CEILING w/ BOND BEAM @ TOP OF WALL. PROVIDE CONTINUOUS WIRE LADDER OR TRUSS TYPE REINFORCEMENT @ 16"O.C. SEE SECTIONS FOR ADDITIONAL REQUIREMENTS.</p>
5	<p><b>EXISTING EXTERIOR WALL:</b>              BRICK TO REMAIN. REMOVE SOFFIT, FACIA, BRICK VENEER, STUD FRAMING, INSULATION AND ANY OTHER ITEMS THAT WILL INTERFERE WITH NEW WORK.</p>
6	<p><b>EXISTING EXTERIOR WALL:</b>              REMOVE SOFFIT, FACIA, BRICK VENEER, STUD FRAMING, INSULATION, BRICK TIES AND ANY OTHER ITEMS THAT INTERFERE WITH NEW VENEER PLASTER SYSTEM. PLASTER SYSTEM TO EXTEND 4" ABOVE CEILING. REMOVE BRICK AND OR 4" BLOCK TO 8" B.F.F.</p>
7	<p><b>EXISTING EXTERIOR WALL:</b>              BRICK TO REMAIN AND EXTEND TO 4" ABOVE NEW CEILING. REMOVE SOFFIT, FACIA, FRAMING, INSULATION AND ANY OTHER ITEMS THAT WILL INTERFERE WITH NEW WORK.</p>

