

WEST NAVARRE INTERMEDIATE SCHOOL
5 CLASSROOM ADDITION

SECTION 15062 - HANGERS AND SUPPORTS FOR HVAC PIPING AND EQUIPMENT

PART 1 - GENERAL

1.1 SUMMARY

A. SECTION INCLUDES:

1. METAL PIPE HANGERS AND SUPPORTS.
2. TRAPEZE PIPE HANGERS.
3. THERMAL-HANGER SHIELD INSERTS.
4. FASTENER SYSTEMS.
5. EQUIPMENT SUPPORTS.

1.2 ACTION SUBMITTALS

A. PRODUCT DATA: FOR EACH TYPE OF PRODUCT INDICATED.

B. SHOP DRAWINGS: SHOW FABRICATION AND INSTALLATION DETAILS AND INCLUDE CALCULATIONS FOR THE FOLLOWING; INCLUDE PRODUCT DATA FOR COMPONENTS:

1. TRAPEZE PIPE HANGERS.
2. EQUIPMENT SUPPORTS.

1.3 INFORMATIONAL SUBMITTALS

A. WELDING CERTIFICATES.

1.4 QUALITY ASSURANCE

A. STRUCTURAL STEEL WELDING QUALIFICATIONS: QUALIFY PROCEDURES AND PERSONNEL ACCORDING TO AWS D1.1/D1.1M, "STRUCTURAL WELDING CODE - STEEL."

B. PIPE WELDING QUALIFICATIONS: QUALIFY PROCEDURES AND OPERATORS ACCORDING TO ASME BOILER AND PRESSURE VESSEL CODE.

PART 2 - PRODUCTS

2.1 METAL PIPE HANGERS AND SUPPORTS

A. CARBON-STEEL PIPE HANGERS AND SUPPORTS:

1. DESCRIPTION: MSS SP-58, TYPES 1 THROUGH 58, FACTORY-FABRICATED COMPONENTS.
2. GALVANIZED METALLIC COATINGS: PREGALVANIZED OR HOT DIPPED.
3. NONMETALLIC COATINGS: PLASTIC COATING, JACKET, OR LINER.

WEST NAVARRE INTERMEDIATE SCHOOL
5 CLASSROOM ADDITION

4. PADDED HANGERS: HANGER WITH FIBERGLASS OR OTHER PIPE INSULATION PAD OR CUSHION TO SUPPORT BEARING SURFACE OF PIPING.
5. HANGER RODS: CONTINUOUS-THREAD ROD, NUTS, AND WASHER MADE OF CARBON STEEL.

B. STAINLESS-STEEL PIPE HANGERS AND SUPPORTS:

1. DESCRIPTION: MSS SP-58, TYPES 1 THROUGH 58, FACTORY-FABRICATED COMPONENTS.
2. PADDED HANGERS: HANGER WITH FIBERGLASS OR OTHER PIPE INSULATION PAD OR CUSHION TO SUPPORT BEARING SURFACE OF PIPING.
3. HANGER RODS: CONTINUOUS-THREAD ROD, NUTS, AND WASHER MADE OF STAINLESS STEEL.

C. COPPER PIPE HANGERS:

1. DESCRIPTION: MSS SP-58, TYPES 1 THROUGH 58, COPPER-COATED-STEEL, FACTORY-FABRICATED COMPONENTS.
2. HANGER RODS: CONTINUOUS-THREAD ROD, NUTS, AND WASHER MADE OF COPPER-COATED STEEL OR STAINLESS STEEL.

2.2 TRAPEZE PIPE HANGERS

- A. DESCRIPTION: MSS SP-69, TYPE 59, SHOP- OR FIELD-FABRICATED PIPE-SUPPORT ASSEMBLY MADE FROM STRUCTURAL CARBON-STEEL SHAPES WITH MSS SP-58 CARBON-STEEL HANGER RODS, NUTS, SADDLES, AND U-BOLTS.**

2.3 THERMAL-HANGER SHIELD INSERTS

- A. INSULATION-INSERT MATERIAL FOR COLD PIPING: ASTM C 552, TYPE II CELLULAR GLASS WITH 100-PSIG OR ASTM C 591, TYPE VI, GRADE 1 POLYISOCYANURATE WITH 125-PSIG MINIMUM COMPRESSIVE STRENGTH AND VAPOR BARRIER.**
- B. INSULATION-INSERT MATERIAL FOR HOT PIPING: WATER-REPELLENT TREATED, ASTM C 533, TYPE I CALCIUM SILICATE WITH 100-PSIG OR ASTM C 591, TYPE VI, GRADE 1 POLYISOCYANURATE WITH 125-PSIG MINIMUM COMPRESSIVE STRENGTH.**
- C. FOR TRAPEZE OR CLAMPED SYSTEMS: INSERT AND SHIELD SHALL COVER ENTIRE CIRCUMFERENCE OF PIPE.**
- D. FOR CLEVIS OR BAND HANGERS: INSERT AND SHIELD SHALL COVER LOWER 180 DEGREES OF PIPE.**
- E. INSERT LENGTH: EXTEND 2 INCHES BEYOND SHEET METAL SHIELD FOR PIPING OPERATING BELOW AMBIENT AIR TEMPERATURE.**

2.4 FASTENER SYSTEMS

- A. POWDER-ACTUATED FASTENERS: THREADED-STEEL STUD, FOR USE IN HARDENED PORTLAND CEMENT CONCRETE WITH PULL-OUT, TENSION, AND SHEAR CAPACITIES APPROPRIATE FOR SUPPORTED LOADS AND BUILDING MATERIALS WHERE USED.**

WEST NAVARRE INTERMEDIATE SCHOOL
5 CLASSROOM ADDITION

- B. MECHANICAL-EXPANSION ANCHORS: INSERT-WEDGE-TYPE, ZINC-COATED OR STAINLESS- STEEL ANCHORS, FOR USE IN HARDENED PORTLAND CEMENT CONCRETE; WITH PULL-OUT, TENSION, AND SHEAR CAPACITIES APPROPRIATE FOR SUPPORTED LOADS AND BUILDING MATERIALS WHERE USED.

2.5 EQUIPMENT SUPPORTS

- A. DESCRIPTION: WELDED, SHOP- OR FIELD-FABRICATED EQUIPMENT SUPPORT MADE FROM STRUCTURAL CARBON-STEEL SHAPES.

2.6 MISCELLANEOUS MATERIALS

- A. STRUCTURAL STEEL: ASTM A 36/A 36M, CARBON-STEEL PLATES, SHAPES, AND BARS; BLACK AND GALVANIZED.
- B. GROUT: ASTM C 1107, FACTORY-MIXED AND -PACKAGED, DRY, HYDRAULIC-CEMENT, NONSHRINK AND NONMETALLIC GROUT; SUITABLE FOR INTERIOR AND EXTERIOR APPLICATIONS.
 - 1. PROPERTIES: NON-STAINING, NONCORROSIVE, AND NONGASEOUS.
 - 2. DESIGN MIX: 5000-PSI, 28-DAY COMPRESSIVE STRENGTH.

PART 3 - EXECUTION

3.1 HANGER AND SUPPORT INSTALLATION

- A. METAL PIPE-HANGER INSTALLATION: COMPLY WITH MSS SP-69 AND MSS SP-89. INSTALL HANGERS, SUPPORTS, CLAMPS, AND ATTACHMENTS AS REQUIRED TO PROPERLY SUPPORT PIPING FROM THE BUILDING STRUCTURE.
- B. METAL TRAPEZE PIPE-HANGER INSTALLATION: COMPLY WITH MSS SP-69 AND MSS SP-89. ARRANGE FOR GROUPING OF PARALLEL RUNS OF HORIZONTAL PIPING, AND SUPPORT TOGETHER ON FIELD-FABRICATED TRAPEZE PIPE HANGERS.
 - 1. PIPES OF VARIOUS SIZES: SUPPORT TOGETHER AND SPACE TRAPEZES FOR SMALLEST PIPE SIZE OR INSTALL INTERMEDIATE SUPPORTS FOR SMALLER DIAMETER PIPES AS SPECIFIED FOR INDIVIDUAL PIPE HANGERS.
 - 2. FIELD FABRICATE FROM ASTM A 36/A 36M, CARBON-STEEL SHAPES SELECTED FOR LOADS BEING SUPPORTED. WELD STEEL ACCORDING TO AWS D1.1/D1.1M.
- C. THERMAL-HANGER SHIELD INSTALLATION: INSTALL IN PIPE HANGER OR SHIELD FOR INSULATED PIPING.
- D. FASTENER SYSTEM INSTALLATION:
 - 1. INSTALL POWDER-ACTUATED FASTENERS FOR USE IN LIGHTWEIGHT CONCRETE OR CONCRETE SLABS LESS THAN 4 INCHES THICK IN CONCRETE AFTER CONCRETE IS PLACED AND COMPLETELY CURED. USE OPERATORS THAT ARE LICENSED BY POWDER-ACTUATED TOOL MANUFACTURER. INSTALL FASTENERS ACCORDING TO POWDER-ACTUATED TOOL MANUFACTURER'S OPERATING MANUAL.

WEST NAVARRE INTERMEDIATE SCHOOL
5 CLASSROOM ADDITION

2. INSTALL MECHANICAL-EXPANSION ANCHORS IN CONCRETE AFTER CONCRETE IS PLACED AND COMPLETELY CURED. INSTALL FASTENERS ACCORDING TO MANUFACTURER'S WRITTEN INSTRUCTIONS.
- E. INSTALL HANGERS AND SUPPORTS COMPLETE WITH NECESSARY ATTACHMENTS, INSERTS, BOLTS, RODS, NUTS, WASHERS, AND OTHER ACCESSORIES.
- F. EQUIPMENT SUPPORT INSTALLATION: FABRICATE FROM WELDED-STRUCTURAL-STEEL SHAPES.
- G. INSTALL HANGERS AND SUPPORTS TO ALLOW CONTROLLED THERMAL AND SEISMIC MOVEMENT OF PIPING SYSTEMS, TO PERMIT FREEDOM OF MOVEMENT BETWEEN PIPE ANCHORS, AND TO FACILITATE ACTION OF EXPANSION JOINTS, EXPANSION LOOPS, EXPANSION BENDS, AND SIMILAR UNITS.
- H. INSTALL LATERAL BRACING WITH PIPE HANGERS AND SUPPORTS TO PREVENT SWAYING.
- I. INSTALL BUILDING ATTACHMENTS WITHIN CONCRETE SLABS OR ATTACH TO STRUCTURAL STEEL. INSTALL ADDITIONAL ATTACHMENTS AT CONCENTRATED LOADS, INCLUDING VALVES, FLANGES, AND STRAINERS, [NPS 2-1/2] <INSERT SIZE> AND LARGER AND AT CHANGES IN DIRECTION OF PIPING. INSTALL CONCRETE INSERTS BEFORE CONCRETE IS PLACED; FASTEN INSERTS TO FORMS AND INSTALL REINFORCING BARS THROUGH OPENINGS AT TOP OF INSERTS.
- J. LOAD DISTRIBUTION: INSTALL HANGERS AND SUPPORTS SO THAT PIPING LIVE AND DEAD LOADS AND STRESSES FROM MOVEMENT WILL NOT BE TRANSMITTED TO CONNECTED EQUIPMENT.
- K. PIPE SLOPES: INSTALL HANGERS AND SUPPORTS TO PROVIDE INDICATED PIPE SLOPES AND TO NOT EXCEED MAXIMUM PIPE DEFLECTIONS ALLOWED BY ASME B31.9 FOR BUILDING SERVICES PIPING.
- L. INSULATED PIPING:
 1. ATTACH CLAMPS AND SPACERS TO PIPING.
 - A. PIPING OPERATING ABOVE AMBIENT AIR TEMPERATURE: CLAMP MAY PROJECT THROUGH INSULATION.
 - B. PIPING OPERATING BELOW AMBIENT AIR TEMPERATURE: USE THERMAL-HANGER SHIELD INSERT WITH CLAMP SIZED TO MATCH OD OF INSERT.
 - C. DO NOT EXCEED PIPE STRESS LIMITS ALLOWED BY ASME B31.9 FOR BUILDING SERVICES PIPING.
 2. INSTALL MSS SP-58, TYPE 39, PROTECTION SADDLES IF INSULATION WITHOUT VAPOR BARRIER IS INDICATED. FILL INTERIOR VOIDS WITH INSULATION THAT MATCHES ADJOINING INSULATION.
 - A. OPTION: THERMAL-HANGER SHIELD INSERTS MAY BE USED. INCLUDE STEEL WEIGHT-DISTRIBUTION PLATE FOR PIPE NPS 4 AND LARGER IF PIPE IS INSTALLED ON ROLLERS.
 3. INSTALL MSS SP-58, TYPE 40, PROTECTIVE SHIELDS ON COLD PIPING WITH VAPOR BARRIER. SHIELDS SHALL SPAN AN ARC OF 180 DEGREES.

WEST NAVARRE INTERMEDIATE SCHOOL
5 CLASSROOM ADDITION

- A. OPTION: THERMAL-HANGER SHIELD INSERTS MAY BE USED. INCLUDE STEEL WEIGHT-DISTRIBUTION PLATE FOR PIPE NPS 4 AND LARGER IF PIPE IS INSTALLED ON ROLLERS.
 - 4. SHIELD DIMENSIONS FOR PIPE: NOT LESS THAN THE FOLLOWING:
 - A. NPS 1/4 TO NPS 3-1/2: 12 INCHES LONG AND 0.048 INCH THICK.
 - B. NPS 4: 12 INCHES LONG AND 0.06 INCH THICK.
 - C. NPS 5 AND NPS 6: 18 INCHES LONG AND 0.06 INCH THICK.
 - D. NPS 8 TO NPS 14: 24 INCHES LONG AND 0.075 INCH THICK.
 - E. NPS 16 TO NPS 24: 24 INCHES LONG AND 0.105 INCH THICK.
 - 5. PIPES NPS 8 AND LARGER: INCLUDE WOOD OR REINFORCED CALCIUM-SILICATE-INSULATION INSERTS OF LENGTH AT LEAST AS LONG AS PROTECTIVE SHIELD.
 - 6. THERMAL-HANGER SHIELDS: INSTALL WITH INSULATION SAME THICKNESS AS PIPING INSULATION.
- 3.2 EQUIPMENT SUPPORTS
- A. FABRICATE STRUCTURAL-STEEL STANDS TO SUSPEND EQUIPMENT FROM STRUCTURE OVERHEAD OR TO SUPPORT EQUIPMENT ABOVE FLOOR.
 - B. GROUTING: PLACE GROUT UNDER SUPPORTS FOR EQUIPMENT AND MAKE BEARING SURFACE SMOOTH.
 - C. PROVIDE LATERAL BRACING, TO PREVENT SWAYING, FOR EQUIPMENT SUPPORTS.
- 3.3 METAL FABRICATIONS
- A. CUT, DRILL, AND FIT MISCELLANEOUS METAL FABRICATIONS FOR TRAPEZE PIPE HANGERS AND EQUIPMENT SUPPORTS.
 - B. FIT EXPOSED CONNECTIONS TOGETHER TO FORM HAIRLINE JOINTS. FIELD WELD CONNECTIONS THAT CANNOT BE SHOP WELDED BECAUSE OF SHIPPING SIZE LIMITATIONS.
 - C. FIELD WELDING: COMPLY WITH AWS D1.1/D1.1M PROCEDURES FOR SHIELDED, METAL ARC WELDING; APPEARANCE AND QUALITY OF WELDS; AND METHODS USED IN CORRECTING WELDING WORK; AND WITH THE FOLLOWING:
 - 1. USE MATERIALS AND METHODS THAT MINIMIZE DISTORTION AND DEVELOP STRENGTH AND CORROSION RESISTANCE OF BASE METALS.
 - 2. OBTAIN FUSION WITHOUT UNDERCUT OR OVERLAP.
 - 3. REMOVE WELDING FLUX IMMEDIATELY.
 - 4. FINISH WELDS AT EXPOSED CONNECTIONS SO NO ROUGHNESS SHOWS AFTER FINISHING AND SO CONTOURS OF WELDED SURFACES MATCH ADJACENT CONTOURS.
- 3.4 ADJUSTING
- A. HANGER ADJUSTMENTS: ADJUST HANGERS TO DISTRIBUTE LOADS EQUALLY ON ATTACHMENTS AND TO ACHIEVE INDICATED SLOPE OF PIPE.

WEST NAVARRE INTERMEDIATE SCHOOL
5 CLASSROOM ADDITION

- B. TRIM EXCESS LENGTH OF CONTINUOUS-THREAD HANGER AND SUPPORT RODS TO 1-1/2 INCHES.

3.5 PAINTING

- A. TOUCHUP: CLEAN FIELD WELDS AND ABRADED AREAS OF SHOP PAINT. PAINT EXPOSED AREAS IMMEDIATELY AFTER ERECTING HANGERS AND SUPPORTS. USE SAME MATERIALS AS USED FOR SHOP PAINTING. COMPLY WITH SSPC-PA 1 REQUIREMENTS FOR TOUCHING UP FIELD-PAINTED SURFACES.

- 1. APPLY PAINT BY BRUSH OR SPRAY TO PROVIDE A MINIMUM DRY FILM THICKNESS OF 2.0 MILS.

- B. GALVANIZED SURFACES: CLEAN WELDS, BOLTED CONNECTIONS, AND ABRADED AREAS AND APPLY GALVANIZING-REPAIR PAINT TO COMPLY WITH ASTM A 780.

3.6 HANGER AND SUPPORT SCHEDULE

- A. SPECIFIC HANGER AND SUPPORT REQUIREMENTS ARE IN SECTIONS SPECIFYING PIPING SYSTEMS AND EQUIPMENT.
- B. COMPLY WITH MSS SP-69 FOR PIPE-HANGER SELECTIONS AND APPLICATIONS THAT ARE NOT SPECIFIED IN PIPING SYSTEM SECTIONS.
- C. USE HANGERS AND SUPPORTS WITH GALVANIZED METALLIC COATINGS FOR PIPING AND EQUIPMENT THAT WILL NOT HAVE FIELD-APPLIED FINISH.
- D. USE NONMETALLIC COATINGS ON ATTACHMENTS FOR ELECTROLYTIC PROTECTION WHERE ATTACHMENTS ARE IN DIRECT CONTACT WITH COPPER TUBING.
- E. USE CARBON-STEEL PIPE HANGERS AND SUPPORTS AND METAL TRAPEZE PIPE HANGERS AND ATTACHMENTS FOR GENERAL SERVICE APPLICATIONS.
- F. USE STAINLESS-STEEL PIPE HANGERS AND STAINLESS-STEEL OR CORROSION-RESISTANT ATTACHMENTS FOR HOSTILE ENVIRONMENT APPLICATIONS.
- G. USE COPPER-PLATED PIPE HANGERS AND COPPER OR STAINLESS-STEEL ATTACHMENTS FOR COPPER PIPING AND TUBING.
- H. USE PADDED HANGERS FOR PIPING THAT IS SUBJECT TO SCRATCHING.
- I. USE THERMAL-HANGER SHIELD INSERTS FOR INSULATED PIPING AND TUBING.
- J. HORIZONTAL-PIPING HANGERS AND SUPPORTS: UNLESS OTHERWISE INDICATED AND EXCEPT AS SPECIFIED IN PIPING SYSTEM SECTIONS, INSTALL THE FOLLOWING TYPES:
 - 1. ADJUSTABLE, STEEL CLEVIS HANGERS (MSS TYPE 1): FOR SUSPENSION OF NONINSULATED OR INSULATED, STATIONARY PIPES NPS 1/2 TO NPS 30.
 - 2. YOKE-TYPE PIPE CLAMPS (MSS TYPE 2): FOR SUSPENSION OF UP TO 1050 DEG F, PIPES NPS 4 TO NPS 24, REQUIRING UP TO 4 INCHES OF INSULATION.
 - 3. CARBON- OR ALLOY-STEEL, DOUBLE-BOLT PIPE CLAMPS (MSS TYPE 3): FOR SUSPENSION OF PIPES NPS 3/4 TO NPS 36, REQUIRING CLAMP FLEXIBILITY AND UP TO 4 INCHES OF INSULATION.

WEST NAVARRE INTERMEDIATE SCHOOL
5 CLASSROOM ADDITION

4. ADJUSTABLE, STEEL BAND HANGERS (MSS TYPE 7): FOR SUSPENSION OF NONINSULATED, STATIONARY PIPES NPS 1/2 TO NPS 8.
 5. U-BOLTS (MSS TYPE 24): FOR SUPPORT OF HEAVY PIPES NPS 1/2 TO NPS 30.
 6. PIPE SADDLE SUPPORTS (MSS TYPE 36): FOR SUPPORT OF PIPES NPS 4 TO NPS 36, WITH STEEL-PIPE BASE STANCHION SUPPORT AND CAST-IRON FLOOR FLANGE OR CARBON-STEEL PLATE.
 7. PIPE STANCHION SADDLES (MSS TYPE 37): FOR SUPPORT OF PIPES NPS 4 TO NPS 36, WITH STEEL-PIPE BASE STANCHION SUPPORT AND CAST-IRON FLOOR FLANGE OR CARBON-STEEL PLATE, AND WITH U-BOLT TO RETAIN PIPE.
 8. SINGLE-PIPE ROLLS (MSS TYPE 41): FOR SUSPENSION OF PIPES NPS 1 TO NPS 30, FROM TWO RODS IF LONGITUDINAL MOVEMENT CAUSED BY EXPANSION AND CONTRACTION MIGHT OCCUR.
 9. COMPLETE PIPE ROLLS (MSS TYPE 44): FOR SUPPORT OF PIPES NPS 2 TO NPS 42 IF LONGITUDINAL MOVEMENT CAUSED BY EXPANSION AND CONTRACTION MIGHT OCCUR BUT VERTICAL ADJUSTMENT IS NOT NECESSARY.
- K. VERTICAL-PIPING CLAMPS: UNLESS OTHERWISE INDICATED AND EXCEPT AS SPECIFIED IN PIPING SYSTEM SECTIONS, INSTALL THE FOLLOWING TYPES:
1. EXTENSION PIPE OR RISER CLAMPS (MSS TYPE 8): FOR SUPPORT OF PIPE RISERS NPS 3/4 TO NPS 24.
 2. CARBON- OR ALLOY-STEEL RISER CLAMPS (MSS TYPE 42): FOR SUPPORT OF PIPE RISERS NPS 3/4 TO NPS 24 IF LONGER ENDS ARE REQUIRED FOR RISER CLAMPS.
- L. HANGER-ROD ATTACHMENTS: UNLESS OTHERWISE INDICATED AND EXCEPT AS SPECIFIED IN PIPING SYSTEM SECTIONS, INSTALL THE FOLLOWING TYPES:
1. STEEL TURNBUCKLES (MSS TYPE 13): FOR ADJUSTMENT UP TO 6 INCHES FOR HEAVY LOADS.
 2. STEEL CLEVISES (MSS TYPE 14): FOR 120 TO 450 DEG F PIPING INSTALLATIONS.
- M. BUILDING ATTACHMENTS: UNLESS OTHERWISE INDICATED AND EXCEPT AS SPECIFIED IN PIPING SYSTEM SECTIONS, INSTALL THE FOLLOWING TYPES:
1. STEEL OR MALLEABLE CONCRETE INSERTS (MSS TYPE 18): FOR UPPER ATTACHMENT TO SUSPEND PIPE HANGERS FROM CONCRETE CEILING.
 2. TOP-BEAM C-CLAMPS (MSS TYPE 19): FOR USE UNDER ROOF INSTALLATIONS WITH BAR-JOIST CONSTRUCTION, TO ATTACH TO TOP FLANGE OF STRUCTURAL SHAPE.
 3. SIDE-BEAM OR CHANNEL CLAMPS (MSS TYPE 20): FOR ATTACHING TO BOTTOM FLANGE OF BEAMS, CHANNELS, OR ANGLES.
 4. CENTER-BEAM CLAMPS (MSS TYPE 21): FOR ATTACHING TO CENTER OF BOTTOM FLANGE OF BEAMS.
 5. WELDED BEAM ATTACHMENTS (MSS TYPE 22): FOR ATTACHING TO BOTTOM OF BEAMS IF LOADS ARE CONSIDERABLE AND ROD SIZES ARE LARGE.
 6. C-CLAMPS (MSS TYPE 23): FOR STRUCTURAL SHAPES.
 7. WELDED-STEEL BRACKETS: FOR SUPPORT OF PIPES FROM BELOW, OR FOR SUSPENDING FROM ABOVE BY USING CLIP AND ROD. USE ONE OF THE FOLLOWING FOR INDICATED LOADS:
 - A. LIGHT (MSS TYPE 31): 750 LB.
 - B. MEDIUM (MSS TYPE 32): 1500 LB.
 - C. HEAVY (MSS TYPE 33): 3000 LB.
 8. SIDE-BEAM BRACKETS (MSS TYPE 34): FOR SIDES OF STEEL OR WOODEN BEAMS.

WEST NAVARRE INTERMEDIATE SCHOOL
5 CLASSROOM ADDITION

- 9. PLATE LUGS (MSS TYPE 57): FOR ATTACHING TO STEEL BEAMS IF FLEXIBILITY AT BEAM IS REQUIRED.
- N. SADDLES AND SHIELDS: UNLESS OTHERWISE INDICATED AND EXCEPT AS SPECIFIED IN PIPING SYSTEM SECTIONS, INSTALL THE FOLLOWING TYPES:
 - 1. STEEL-PIPE-COVERING PROTECTION SADDLES (MSS TYPE 39): TO FILL INTERIOR VOIDS WITH INSULATION THAT MATCHES ADJOINING INSULATION.
 - 2. PROTECTION SHIELDS (MSS TYPE 40): OF LENGTH RECOMMENDED IN WRITING BY MANUFACTURER TO PREVENT CRUSHING INSULATION.
 - 3. THERMAL-HANGER SHIELD INSERTS: FOR SUPPORTING INSULATED PIPE.
- O. SPRING HANGERS AND SUPPORTS: UNLESS OTHERWISE INDICATED AND EXCEPT AS SPECIFIED IN PIPING SYSTEM SECTIONS, INSTALL THE FOLLOWING TYPES:
 - 1. SPRING CUSHIONS (MSS TYPE 48): FOR LIGHT LOADS IF VERTICAL MOVEMENT DOES NOT EXCEED 1-1/4 INCHES.
 - 2. SPRING-CUSHION ROLL HANGERS (MSS TYPE 49): FOR EQUIPPING TYPE 41, ROLL HANGER WITH SPRINGS.
 - 3. VARIABLE-SPRING BASE SUPPORTS (MSS TYPE 52): PRESET TO INDICATED LOAD AND LIMIT VARIABILITY FACTOR TO 25 PERCENT TO ALLOW EXPANSION AND CONTRACTION OF PIPING SYSTEM FROM BASE SUPPORT.
- P. COMPLY WITH MSS SP-69 FOR TRAPEZE PIPE-HANGER SELECTIONS AND APPLICATIONS THAT ARE NOT SPECIFIED IN PIPING SYSTEM SECTIONS.
- Q. USE POWDER-ACTUATED FASTENERS OR MECHANICAL-EXPANSION ANCHORS INSTEAD OF BUILDING ATTACHMENTS WHERE REQUIRED IN CONCRETE CONSTRUCTION.

END OF SECTION 15062