

**WEST NAVARRE INTERMEDIATE SCHOOL**  
**5 CLASSROOM ADDITION**

**SECTION 15076 - IDENTIFICATION FOR PLUMBING PIPING AND EQUIPMENT**

**PART 1 - GENERAL**

**1.1 RELATED DOCUMENTS**

- A. DRAWINGS AND GENERAL PROVISIONS OF THE CONTRACT, INCLUDING GENERAL AND SUPPLEMENTARY CONDITIONS AND DIVISION 01 SPECIFICATION SECTIONS, APPLY TO THIS SECTION.

**1.2 SUMMARY**

- A. SECTION INCLUDES:
  - 1. EQUIPMENT LABELS.
  - 2. PIPE LABELS.
  - 3. VALVE TAGS.

**1.3 COORDINATION**

- A. COORDINATE INSTALLATION OF IDENTIFYING DEVICES WITH COMPLETION OF COVERING AND PAINTING OF SURFACES WHERE DEVICES ARE TO BE APPLIED.
- B. COORDINATE INSTALLATION OF IDENTIFYING DEVICES WITH LOCATIONS OF ACCESS PANELS AND DOORS.
- C. INSTALL IDENTIFYING DEVICES BEFORE INSTALLING ACOUSTICAL CEILINGS AND SIMILAR CONCEALMENT.

**PART 2 - PRODUCTS**

**2.1 EQUIPMENT LABELS**

- A. PLASTIC LABELS FOR EQUIPMENT:
  - 1. MATERIAL AND THICKNESS: MULTILAYER, MULTICOLOR, PLASTIC LABELS FOR MECHANICAL ENGRAVING, 1/8 INCH THICK, AND HAVING PREDRILLED HOLES FOR ATTACHMENT HARDWARE.
  - 2. LETTER COLOR: WHITE.
  - 3. BACKGROUND COLOR: BLACK.
  - 4. MAXIMUM TEMPERATURE: ABLE TO WITHSTAND TEMPERATURES UP TO 160 DEG F.
  - 5. MINIMUM LABEL SIZE: LENGTH AND WIDTH VARY FOR REQUIRED LABEL CONTENT, BUT NOT LESS THAN 2-1/2 BY 3/4 INCH.
  - 6. MINIMUM LETTER SIZE: 1/4 INCH FOR NAME OF UNITS IF VIEWING DISTANCE IS LESS THAN 24 INCHES, 1/2 INCH FOR VIEWING DISTANCES UP TO 72 INCHES, AND PROPORTIONATELY LARGER LETTERING FOR GREATER VIEWING DISTANCES.

**WEST NAVARRE INTERMEDIATE SCHOOL**  
**5 CLASSROOM ADDITION**

INCLUDE SECONDARY LETTERING TWO-THIRDS TO THREE-FOURTHS THE SIZE OF PRINCIPAL LETTERING.

7. FASTENERS: STAINLESS-STEEL RIVETS OR SELF-TAPPING SCREWS.
8. ADHESIVE: CONTACT-TYPE PERMANENT ADHESIVE, COMPATIBLE WITH LABEL AND WITH SUBSTRATE.

- B. LABEL CONTENT: INCLUDE EQUIPMENT'S DRAWING DESIGNATION OR UNIQUE EQUIPMENT NUMBER, DRAWING NUMBERS WHERE EQUIPMENT IS INDICATED (PLANS, DETAILS, AND SCHEDULES), PLUS THE SPECIFICATION SECTION NUMBER AND TITLE WHERE EQUIPMENT IS SPECIFIED.

2.2 PIPE LABELS

- A. GENERAL REQUIREMENTS FOR MANUFACTURED PIPE LABELS: PREPRINTED, COLOR-CODED, WITH LETTERING INDICATING SERVICE, AND SHOWING FLOW DIRECTION.
- B. PRETENSIONED PIPE LABELS: PRECOILED, SEMIRIGID PLASTIC FORMED TO COVER FULL CIRCUMFERENCE OF PIPE AND TO ATTACH TO PIPE WITHOUT FASTENERS OR ADHESIVE.
- C. SELF-ADHESIVE PIPE LABELS: PRINTED PLASTIC WITH CONTACT-TYPE, PERMANENT-ADHESIVE BACKING.
- D. PIPE LABEL CONTENTS: INCLUDE IDENTIFICATION OF PIPING SERVICE USING SAME DESIGNATIONS OR ABBREVIATIONS AS USED ON DRAWINGS, PIPE SIZE, AND AN ARROW INDICATING FLOW DIRECTION.
  1. FLOW-DIRECTION ARROWS: INTEGRAL WITH PIPING SYSTEM SERVICE LETTERING TO ACCOMMODATE BOTH DIRECTIONS, OR AS SEPARATE UNIT ON EACH PIPE LABEL TO INDICATE FLOW DIRECTION.
  2. LETTERING SIZE: AT LEAST 1-1/2 INCHES HIGH.

2.3 VALVE TAGS

- A. VALVE TAGS: STAMPED OR ENGRAVED WITH 1/4-INCH LETTERS FOR PIPING SYSTEM ABBREVIATION AND 1/2-INCH NUMBERS.
  1. TAG MATERIAL: BRASS, 0.032-INCH MINIMUM THICKNESS, AND HAVING PREDRILLED OR STAMPED HOLES FOR ATTACHMENT HARDWARE.
  2. FASTENERS: BRASS WIRE-LINK OR BEADED CHAIN; OR S-HOOK.
- B. VALVE SCHEDULES: FOR EACH PIPING SYSTEM, ON 8-1/2-BY-11-INCH BOND PAPER. TABULATE VALVE NUMBER, PIPING SYSTEM, SYSTEM ABBREVIATION (AS SHOWN ON VALVE TAG), LOCATION OF VALVE (ROOM OR SPACE), NORMAL-OPERATING POSITION (OPEN, CLOSED, OR MODULATING), AND VARIATIONS FOR IDENTIFICATION. MARK VALVES FOR EMERGENCY SHUTOFF AND SIMILAR SPECIAL USES.
  1. VALVE-TAG SCHEDULE SHALL BE INCLUDED IN OPERATION AND MAINTENANCE DATA.

**WEST NAVARRE INTERMEDIATE SCHOOL**  
**5 CLASSROOM ADDITION**

**PART 3 - EXECUTION**

**3.1 PREPARATION**

- A. CLEAN PIPING AND EQUIPMENT SURFACES OF SUBSTANCES THAT COULD IMPAIR BOND OF IDENTIFICATION DEVICES, INCLUDING DIRT, OIL, GREASE, RELEASE AGENTS, AND INCOMPATIBLE PRIMERS, PAINTS, AND ENCAPSULANTS.

**3.2 EQUIPMENT LABEL INSTALLATION**

- A. INSTALL OR PERMANENTLY FASTEN LABELS ON EACH MAJOR ITEM OF MECHANICAL EQUIPMENT.
- B. LOCATE EQUIPMENT LABELS WHERE ACCESSIBLE AND VISIBLE.

**3.3 PIPE LABEL INSTALLATION**

- A. LOCATE PIPE LABELS WHERE PIPING IS EXPOSED OR ABOVE ACCESSIBLE CEILINGS IN FINISHED SPACES; MACHINE ROOMS; ACCESSIBLE MAINTENANCE SPACES SUCH AS SHAFTS, TUNNELS, AND PLENUMS; AND EXTERIOR EXPOSED LOCATIONS AS FOLLOWS:
  - 1. NEAR EACH VALVE AND CONTROL DEVICE.
  - 2. NEAR EACH BRANCH CONNECTION, EXCLUDING SHORT TAKEOFFS FOR FIXTURES AND TERMINAL UNITS. WHERE FLOW PATTERN IS NOT OBVIOUS, MARK EACH PIPE AT BRANCH.
  - 3. NEAR PENETRATIONS THROUGH WALLS, FLOORS, CEILINGS, AND INACCESSIBLE ENCLOSURES.
  - 4. AT ACCESS DOORS, MANHOLES, AND SIMILAR ACCESS POINTS THAT PERMIT VIEW OF CONCEALED PIPING.
  - 5. NEAR MAJOR EQUIPMENT ITEMS AND OTHER POINTS OF ORIGIN AND TERMINATION.
  - 6. SPACED AT MAXIMUM INTERVALS OF 50 FEET ALONG EACH RUN. REDUCE INTERVALS TO 25 FEET IN AREAS OF CONGESTED PIPING AND EQUIPMENT.
  - 7. ON PIPING ABOVE REMOVABLE ACOUSTICAL CEILINGS. OMIT INTERMEDIATELY SPACED LABELS.
- B. PIPE LABEL COLOR SCHEDULE:
  - 1. DOMESTIC WATER PIPING:
    - A. BACKGROUND COLOR: GREEN.
    - B. LETTER COLOR: WHITE.
  - 2. SANITARY WASTE AND STORM DRAINAGE PIPING:
    - A. BACKGROUND COLOR: GREEN.
    - B. LETTER COLOR: WHITE.

**WEST NAVARRE INTERMEDIATE SCHOOL**  
**5 CLASSROOM ADDITION**

3.4 VALVE-TAG INSTALLATION

- A. INSTALL TAGS WITH 2 TAPCON SCREWS WALL TO THE REAR OF VALVES AND CONTROL DEVICES IN PIPING SYSTEMS, EXCEPT CHECK VALVES; VALVES; FIXTURE STOP VALVES; FAUCETS; CONVENIENCE AND LAWN-WATERING HOSE CONNECTIONS; AND SIMILAR ROUGHING-IN CONNECTIONS OF END-USE FIXTURES AND UNITS. LIST TAGGED VALVES IN A VALVE SCHEDULE.

END OF SECTION 15076