

WEST NAVARRE INTERMEDIATE SCHOOL
5 CLASSROOM ADDITION

SECTION 15098 - ESCUTCHEONS FOR HVAC PIPING

PART 1 - GENERAL

1.1 SUMMARY

- A. SECTION INCLUDES:
 - 1. ESCUTCHEONS.

1.2 ACTION SUBMITTALS

- A. PRODUCT DATA: FOR EACH TYPE OF PRODUCT INDICATED.

PART 2 - PRODUCTS

2.1 ESCUTCHEONS

- A. ONE-PIECE, CAST-BRASS TYPE: WITH POLISHED, CHROME-PLATED AND ROUGH-BRASS FINISH AND SETSCREW FASTENER.
- B. ONE-PIECE, DEEP-PATTERN TYPE: DEEP-DRAWN, BOX-SHAPED BRASS WITH CHROME-PLATED FINISH AND SPRING-CLIP FASTENERS.
- C. ONE-PIECE, STAMPED-STEEL TYPE: WITH CHROME-PLATED FINISH AND SPRING-CLIP FASTENERS.

PART 3 - EXECUTION

3.1 INSTALLATION

- A. INSTALL ESCUTCHEONS FOR PIPING PENETRATIONS OF WALLS AND CEILINGS.
- B. INSTALL ESCUTCHEONS WITH ID TO CLOSELY FIT AROUND PIPE, TUBE, AND INSULATION OF PIPING AND WITH OD THAT COMPLETELY COVERS OPENING.
 - 1. ESCUTCHEONS FOR NEW PIPING:
 - A. PIPING WITH FITTING OR SLEEVE PROTRUDING FROM WALL: ONE-PIECE, DEEP-PATTERN TYPE.
 - B. CHROME-PLATED PIPING: ONE-PIECE, CAST-BRASS TYPE WITH POLISHED, CHROME-PLATED FINISH.
 - C. INSULATED PIPING: ONE-PIECE, STAMPED-STEEL TYPE.
 - D. BARE PIPING AT WALL PENETRATIONS IN FINISHED SPACES: ONE-PIECE, CAST-BRASS TYPE WITH POLISHED, CHROME-PLATED FINISH.
 - E. BARE PIPING AT CEILING PENETRATIONS IN FINISHED SPACES: ONE-PIECE, CAST-BRASS TYPE WITH POLISHED, CHROME-PLATED FINISH.

WEST NAVARRE INTERMEDIATE SCHOOL
5 CLASSROOM ADDITION

- F. BARE PIPING IN UNFINISHED SERVICE SPACES: ONE-PIECE, CAST-BRASS TYPE WITH POLISHED, CHROME-PLATED OR ROUGH-BRASS FINISH.
- G. BARE PIPING IN UNFINISHED SERVICE SPACES: ONE-PIECE, STAMPED-STEEL TYPE.
- H. BARE PIPING IN EQUIPMENT ROOMS: ONE-PIECE, CAST-BRASS TYPE WITH POLISHED, CHROME-PLATED OR ROUGH-BRASS FINISH.
- I. BARE PIPING IN EQUIPMENT ROOMS: ONE-PIECE, STAMPED-STEEL TYPE.

3.2 FIELD QUALITY CONTROL

- A. REPLACE BROKEN AND DAMAGED ESCUTCHEONS USING NEW MATERIALS.

END OF SECTION 15098