

ADAMS CONSULTING ENGINEERING, INC.

CONSULTING ENGINEERS

TEL (850) 444-0095

scott@adamscei.com

October 4, 2011

Mike Martin
Pinder-Martin Associates, Inc.
1001 N. 12th Avenue
Pensacola, Florida 32501

RE: 5 Classroom Addition West Navarre Intermediate School – Electrical Clarification

Mr. Martin,

Please include the following electrical items in your next clarification:

- 1. Sheet E2.0: LIGHTING PLAN-WING 3: Provide emergency lighting circuit in a separate dedicated conduit system from emergency lighting fixtures/circuit in Corridor 300 to each emergency lighting fixture in the following rooms: Rooms 313, 313B, 314, and 316.**
- 2. Sheet E2.0: LIGHTING PLAN-WING 5: Provide emergency lighting circuit in a separate dedicated conduit system from emergency lighting fixtures/circuit in Corridor 500 to each emergency lighting fixture in the following rooms: Rooms 510, 510B, 511, 511B, and 512.**

END OF CLARIFICATION

Please call if you have any questions.

Sincerely,
Scott A. Adams, P.E.
Electrical Engineer